

# Product Specification and Maintenance Guide

## PSMG-PMXUT030001.0

<b>Date</b>	July 2021
<b>Code</b>	PMXUT030001.0
<b>Description</b>	Promax Enduro Underground Tank 3000L 1.0m dia

### Specifications

Width (mm)	Height (mm)	Length (mm)	Weight (kg)	Manhole Dia (mm)
1250	1553	3070	150	600

### Standard

Complies with:

- AS/NZS 4020: Products in contact with drinking water
- AS/NZS 2070 (INT): Plastics material for food contact use

### Uses

- Potable Water Storage
- Retention/Detention Stormwater Management
- Waste Storage

### Statement

In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions

Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.

### Maintenance

Description	Action	Frequency
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

**Please note: Entry into this tank is at owners risk.**

### Authorised By:

Promax Engineered Plastics Limited  
PO Box 749, Kerikeri 0245, New Zealand



# Product Specification and Maintenance Guide



<b>Responsibility</b>	The owner/s are responsible for maintenance of the tank.
<b>Post Storm Inspection</b>	Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.
<b>Debris removal programme</b>	If debris is identified in either a regular maintainence check or post storm inspection it is recommended that this is removed by a professional stromwater maintenance provider.

<b>Maintenance records</b>			
	<b>Date</b>	<b>Comments</b>	<b>Completed</b>

