

Product Specification and Maintenance Guide

PSMG-PMXUT060001.2

Date	July 2021
Code	PMXUT060001.2
Description	Promax Underground Tank 6000L 1.2m dia

Specifications

Capacity (L)	Diameter (mm)	Length (mm)	Weight (kg)	Manhole Dia (mm)
6000	1280	6000	250	600

Standard

Complies with:

- AS/NZS 4020: Products in contact with drinking water
- AS/NZS 2070 (INT): Plastics material for food contact use
- AS/NZS 2566:1-1998

Uses

- Potable Water Storage
- Retention/Detention Stormwater Management
- Waste Storage

Statement

In line with today's focus on Ecologically Sustained Development, Green Building Initiatives and 5 Star Ratings, Promax is committed to supplying quality Liquid Storage and Handling Solutions

Promax Plastics confirms that if these tanks are installed according to Good Management practices set out in the Promax Installation Guides, they will perform as stated throughout their intended life.

Maintenance

Description	Action	Frequency
Tank Lid	Remains securely fitted	Bi-Monthly
Inlet/Outlet Fitting	Remains securely fitted with no leakage	Bi-Monthly
Pump	Check Pump, if fitted, for inlet screen blockages	Bi-Monthly
Sediment Build Up	Remains lower than base outlet - if outlet flow becomes restricted remove sediment with vacuum truck. Re-attach tank lid securely.	Half yearly or as necessary

Please note: Entry into this tank is at owners risk.

Authorised By:

Promax Engineered Plastics Limited
PO Box 749, Kerikeri 0245, New Zealand



Product Specification and Maintenance Guide

Responsibility	The owner/s are responsible for maintenance of the tank.
Post Storm Inspection	Following a storm event it is recommended that a full tank inspection is carried out, please refer the maintenance section for guidelines on this.
Debris removal programme	If debris is identified in either a regular maintenance check or post storm inspection it is recommended that this is removed by a professional stormwater maintenance provider.

Maintenance records

Date	Comments	Completed

